

Newly Developed Cloth Media for Low Phosphorus & Water Reuse Applications

WWOA 53rd Annual Conference

October 10, 2019


Matt Castillo, P.E.
mcastillo@msa-ps.com

Outline

- Cloth media
- Chemical addition
- Jar testing
- Why conduct a pilot study?
- Pilot testing protocol
- Platteville Water Resource Recovery Facility
- Cloth media comparison
- Water reuse potential




Surface Filtration

- Many technologies are available
- Media is evolving
 - Granular
 - Compressible
 - 10 μm
 - 5 μm
 - **2 μm - NEW**



Cloth Media – The Basics

- Pile fibers create filtration area
- Backing and filament construction make a difference




Cloth Media - Ultrafiber

- Ultrafiber
 - Newly developed cloth – ultrafiber
 - Originally designed for water pretreatment systems
 - Clean feed source (5-10 mg/L TSS)
 - Designed to improve particle retention
 - “Filtration rating” of 2 micron
 - Fiber construction – 1/2 to 1/3 of microfiber



Filtration and Chemical Addition




Where to Start – Jar Testing


- Should be tailored to closely match actual conditions
- Conditions
 - Sequence of chemical addition
 - Rapid mixing time and intensity
 - Flocculation time and intensity
- Visual Evaluation
 - Time of first floc formation
 - Floc size
 - Floc Quality
 - Settling Rate
- Settled Samples
 - Turbidity
 - Color
 - Particle count
 - Filtered turbidity
 - Phosphorus



Jar Testing



Jar Testing – Dose Response Curve



Pilot Study – Why?

- Advantages
 - New technology uneasiness
 - Hands-on experience
 - Performance assessment at different conditions
 - Influent and effluent constituents
 - High flows and solids loadings
 - Chemical usage – type and volume
 - Chemical contact time
 - Phosphorus speciation
 - Backwashing – frequency and volume
 - Improve startup activities
- Disadvantages
 - Costs: \$5,000 - \$40,000
 - Time

Pilot Study – Side by Side Comparison



Onsite Pilot Testing – The Protocol

- Agree on protocol
- Get the biggest bang for your buck
- Plan for normal or upset conditions
- Sampling schedule
- Lab testing requirements
- Daily schedule
- Staffing plan



Protocol – Daily Schedule

| Proposed Schedule | | | |
|-------------------|-------------|-------------------------------------|-------------------------------|
| | Day | Test | HLR (gpm/ft ²) |
| 1 | Mon | Equipment arrives on site and setup | N/A |
| 2 | Tues | Setup | N/A |
| 3 | Wed | Finish setup and start flow | 3.25 |
| 4 | <u>Thur</u> | Metal salt & polymer optimization | 3.25 |
| 5 | Fri | Metal salt & polymer optimization | 3.25 |
| 6 | Mon | Metal salt & polymer optimization | 3.25 |
| 7 | Tues | Steady State | 3.25 |
| 8 | Wed | Steady State | 3.25 |
| 9 | <u>Thur</u> | Steady State | 3.25 |
| 10 | Fri | Maximum Flow | 6.5 |
| 11 | Mon | Metal salt & polymer optimization | 2.0 |
| 12 | Tues | Metal salt & polymer optimization | 2.0 |
| 13 | Wed | Steady State | 2.0 |
| 14 | <u>Thur</u> | Steady State | 2.0 |
| 15 | Fri | Steady State | 2.0 |
| 16 | Mon | Maximum Flow | 4.0 |

Protocol – Sampling Requirements

| Sampling Schedule | | |
|-----------------------------|-------------------------------|---------------------------|
| Influent | Onsite Lab | 3 rd Party Lab |
| TSS (pre chemical) | - | 2 Composite/day |
| TSS (post chemical) | - | 2 grab/day |
| Total Phosphorus | 2 Composite/day 2 Grab/day | 2 Composite/day |
| Soluble Phosphorus | 2 Composite/day 2 Grab/day | |
| Soluble Reactive Phosphorus | 2 Composite/day 2 Grab/day | |
| Particle Size Analysis | 2 Composite/day | |
| Effluent | | |
| TSS | - | 2 Composite/day |
| Total Phosphorus | 2 Composite/day 2 Grab/day | 2 Composite/day |
| Soluble Phosphorus | 2 Composite/day 2 Grab/day | |
| Soluble Reactive Phosphorus | 2 Composite/day 2 Grab/day | |
| Particle Size Analysis | 2 Composite/day | |

Platteville Water Resource Recovery Facility

- Located in southwestern WI
- Current population of 12,200
- Annual average of design flow = 2.05 MGD
- Current annual average = 1.0 MGD
- Integrated biological treatment system
 - Primary settlers
 - Trickling filters
 - Intermediate clarifiers
 - Aeration basins
 - Secondary clarifiers
 - Sand filters
 - Disinfection

Platteville WRRF – Aerial



Phosphorus Compliance Schedule

| Required Action | Year Due |
|-----------------------------------|----------|
| Year 1 – OER | 2015 |
| Year 2 – Status Report | 2016 |
| Year 3 – Preliminary Alternatives | 2017 |
| Year 4 – Final Alternatives | 2018 |
| Achieve Compliance – 0.075 mg/L | 2023 |

Phosphorus Compliance

- Chemical phosphorus removal study
 - Multipoint chemical addition
 - Intermediate clarifier effluent
 - Sand filter influent
 - Results indicate that effluent phosphorus < 0.3 mg/L is possible
- Watershed
 - 3,000 lb annually
- WWTF upgrades – surface filtration
- MDV

Testing Protocol

- Two types of cloth media
 - Standard cloth – microfiber
 - “Filtration rating” of 5 micron
 - Ultrafiber
 - “Filtration rating” of 2 micron
- Standard cloth – microfiber
 - Average HLR = 3.25 gpm/ft²
 - Peak HLR = 6.5 gpm/ft²
 - Design SLR = 2.0 ppd/ft²
- Ultrafiber
 - Average HLR = 2.0 gpm/ft²
 - Peak HLR = 4.0 gpm/ft²
 - Design SLR = 1.0 ppd/ft²




Pilot Trailer


- Commercial unit, full-scale, single disk
- 10.8 ft² of effective filtration area
- Chemical feed pumps
- Flocculation tanks
- Data monitoring
 - Influent and effluent turbidity
 - Influent and waste flow
 - Tank level
 - Influent and effluent ortho-phosphorus




Results – Particle Removal




Particle Removal




Results – Total Suspended Solids




Phosphorus – Influent Speciation – SNRP




Phosphorus – Effluent Speciation – SNRP




Phosphorus – Effluent Speciation – SNRP




Phosphorus – Influent Speciation – Orthophosphate




Phosphorus – Effluent Speciation – Orthophosphate




Phosphorus – Effluent Speciation – Orthophosphate




Phosphorus – Influent Speciation – Insoluble Forms




Phosphorus – Effluent Speciation – Insoluble Forms




Phosphorus – Effluent Speciation – Insoluble Forms




Results – Microfiber Adjustment Period




Results – Microfiber Optimization



Results – Ultrafiber Optimization



Overall Summary of Results – Phosphorus



Results – Avg. and Peak HLRs

| Cloth Type | HLR (gpm) | Avg. Molar Ratio (mol Fe:mol P) | Average Total Phosphorus (TP) | | |
|------------|-----------|---------------------------------|-------------------------------|----------|---------|
| | | | Influent | Effluent | Removal |
| | | | (mg/L) | (mg/L) | (%) |
| Microfiber | 3.25 | 1.81 | 0.73 | 0.077 | 89.1 |
| | 6.50 | 1.92 | 0.64 | 0.098 | 84.5 |
| Ultrafiber | 2.0 | 3.77 | 0.36 | 0.053 | 84.7 |
| | 4.0 | 2.33 | 0.47 | 0.062 | 86.9 |

Results – Total Waste Flow

- Automatically initiated at 12” differential
- Cleans by drawing filtrate backwards through cloth
- Solids at bottom of tank are wasted using same backwash pump

| Cloth | No Chemical | Ferric | Ferric + Polymer | High Solids |
|------------|-------------|--------|------------------|-------------|
| Microfiber | - | 3% | 3.5% | - |
| Ultrafiber | 7% | 10% | 11% | 12.5% |

Results – Laboratory Analysis

- Results from Lab 2 were suspiciously low compared to the other labs
- On average, influent data from onsite and Lab 1 were 27% and 31% greater than Lab 2, respectively
- Effluent results showed greater differences
 - Onsite and Lab 1 were 60% and 44% greater than Lab 2
- All of Lab 2 data was removed from the data analysis

| Sample Location | Laboratory | | |
|-----------------|------------|-------|-------|
| | Onsite | Lab 1 | Lab 2 |
| Influent | 0.59 | 0.61 | 0.47 |
| Effluent | 0.121 | 0.109 | 0.076 |

Results – Upset Conditions & High Solids

- High solids sources: MLSS, recycling backwash
- Backwash recycled at 3% of forward flow
- Could recycling solids reduce effluent concentrations and the need for chemical?

| Cloth | Influent TSS (mg/L) | Effluent TSS (mg/L) | Influent Phosphorus (mg/L) | Effluent Phosphorus (mg/L) |
|------------|---------------------|---------------------|----------------------------|----------------------------|
| Microfiber | 19 | 2 | 0.95 | 0.087 |
| Ultrafiber | 11 | 1 | 0.60 | 0.060 |

Potential for Water Reuse

- Testing completed in Saint Johns County, FL
- Filter influent was spiked with inactivated cryptosporidium and giardia lamblia
- 2.2 log removal of cryptosporidium
- 3.5 log removal of giardia

| | Cryptosporidium (oocysts/100 L) | Giardia (cysts/100 L) |
|------------------|--|----------------------------------|
| Influent | 13,600 | 6,800 |
| Effluent #1 | 103 | 4 |
| Effluent #2 | 98 | 1 |
| Effluent #3 | 67 | 2 |
| Average Effluent | 89 | 2.3 |

Summary

- Onsite piloting can provide valuable hands-on experience for operators
- Critical aspects of onsite testing
 - Protocol agreement
 - Laboratory requirements
- Upstream performance is critical
- Chemical and SNRP play a critical role
- Tighter media construction results in better removal rates
- Ultrafiber appears to have potential for water reuse applications
- Disadvantages of tighter media construction include higher wasting rates and lower design flow and solids loading rates

