

THE PHOSPHORUS JOURNEY: ONE PLANT'S STORY

WWOA 50th Annual Conference October 11th - 14th, 2016



Dave Arnott P.E.
Ruekert & Mielke, Inc.

Topics Covered



topics

1. Background

2. Preliminary Studies

3. Permit Compliance Schedule

4. Optimization

5. Summary

Background



Background


Water Pollution Control Facility

- Activated Sludge
- Extended Aeration
- Advanced Treatment
 - Nitrification/Denit.
 - Tertiary Filters
- Design ADF: 3.4 MGD
- New Permit July 2012
 - Interim P Limit: 0.6 mg/L
 - Final P Limit: 0.075 mg/L
- Discharge to Rubicon River → Rock River



Preliminary Studies

Combine
with the
Village
of
Slinger?



Preliminary Studies

Watershed Solution Feasibility



Site Specific Criteria

Preliminary Studies

Watershed Solution Feasibility



Filter Strips

Watershed Solution Feasibility

Watershed

Plant Upgrade

No New Building
Reuse deep bed filter
concrete superstructure

Capital Cost
= \$2.7 million

20-year 4% i-rate
annualized cost
= \$175,370

Incremental cost (0.45
mg/L to 0.06 mg/L =
\$109/lb P

Filter strips
= **\$39/lb P**

Permit Compliance Schedule

Operation and Needs Review/Optimization

Due June 30, 2013

“...report shall evaluate collected effluent data, possible source reduction measures, operational improvements or other minor facility modifications that would enable compliance with the final phosphorus WQBEL or some improved level of effluent quality...”

Permit Compliance Schedule

Facilities Planning Status Report

Due June 30, 2014

This report shall provide an update on the permittee's progress in evaluating feasible alternatives which may include: facility upgrading, consolidation with other sewerage systems, alternative effluent discharge locations, an Adaptive Management Plan, Water Quality Trading plan or a water quality standards variance



Permit Compliance Schedule

Preliminary Facilities Planning

Due June 30, 2015

- Ultrafiltration
- Disk Filtration (cloth)
- Disk Filtration (membrane)
- Ballasted Sedimentation
- Continuous Backwash Filter
- Rare Earth Product/Biological P Removal

Permit Compliance Schedule

Preliminary Facilities Planning

Process

Equipment Cost

- | | |
|---------------------------------|---------------|
| □ Ultrafiltration | □ \$4,567,000 |
| □ Disk Filtration (cloth) | □ \$974,000 |
| □ Disk Filtration (membrane) | □ \$1,026,000 |
| □ Ballasted Sedimentation | □ \$1,153,000 |
| □ Continuous Backwash Filter | □ \$1,950,000 |
| □ Rare Earth Product/Biological | □ \$0 |

Use Anthracite Filters Concrete

Superstructure, No new Bldg.

Permit Compliance Schedule

Final Facilities Planning

Due June 30, 2016

- Bio P / Rare Earth Product Alternative
 - No Further Updates Needed
- Backup Plan – Bio P with Disk Filtration (cloth or membrane)
- Backup Plan – Bio P Coupled with WQT
 - 0.15 mg/L TP → 0.075 mg/L TP



Optimization

On-line Ortho P Analyzer

- Secondary clarifier effluent
- Heavy industrial loading
- In place July of 2014



Optimization

Constant Chemical Feed

- ❑ Replaced pump with smaller unit
- ❑ Continuous operation instead of intermittent
- ❑ In place July of 2014



Optimization

Industrial Coordination

- Grande Cheese
- Hartford Finishing

Went to P-Free Products

Effluent 100 mg/L → 40 mg/L



Optimization

Rare Earth Product

SorbX-100 rare earth technology forms strong, crystalline bonds with phosphorus.



SorbX -100 reacts to form a phosphate precipitant.

Traditional coagulants form amorphous “clouds” in solution. Phosphorus is easily released back into solution.



Iron reacts to form a phosphate adsorbent.

SorbX-100 has a unique mode of action resulting in rapid and stable precipitation of phosphorus. SorbX-100 generates less chemical sludge than other coagulants due to its high reactivity with phosphate based compounds.

Optimization

Rare Earth Product

Advantages

- Less sludge produced
- Thicker MLSS conc.
- More efficient than ferrous chloride
- Lower SVI
- NP water, no smell


Disadvantages

- Higher unit cost
- Unknown market stability and distribution network
- Unknown future pricing
- Few competitors

Optimization

- **Bio P in Ditch**
 - **Relative DO deficit**
 - **ORP**
 - **Remove discs in outer**
 - **Mixing OK**
 - **Save energy**







AERATION BASIN

NO SCALE


Optimization-Pilot Data




Optimization-Pilot Data



Optimization-Pilot Data



Optimization-Pilot Data




Summary

- Plant demonstrated it can meet 0.075 mg/L consistently
 - Rare earth, Bio P
 - ORP variable
- Optimization takes time
 - Seasonal fluctuations



Summary

- Bio P and Rare Earth
 - ▣ No Add'l Upgrades
- Backup Bio P and Disc Filter
 - ▣ Membrane
 - ▣ Cloth
- Backup Bio P with WQT
 - ▣ 0.15 mg/L TP → 0.075 mg/L TP
- Expect New Permit 2017
 - ▣ 0.075 mg/L TP



QUESTIONS?

Dave Arnott

262-542-5733

darnott@ruekert-mielke.com

Dave Piquett

262-673-2423

dpiquett@ci.hartford.wi.us