


RE-ENGINEERING O&M PRACTICES TO GET NITROGEN & PHOSPHORUS REMOVAL WITHOUT FACILITY UPGRADES

GRANT WEAVER, PE & WASTEWATER OPERATOR

WISCONSIN WASTEWATER OPERATORS ASSOCIATION
WISCONSIN DELLS, WI – OCTOBER 11, 2012



Re-Engineering O&M to get N+P Removal



Nitrogen Removal
Science
Design Theory
Phosphorus Removal
Science
Design Theory
O&M Strategies
Case Studies



Traditional Approach



your design solution
{ web video print app }



Cost of Facility Upgrades

\$85 billion taxpayer dollars

spent building 15,000 wastewater treatment plants (1972-Present).



\$250 billion

“needed” to fix existing treatment plants and CSO pollution (2010 EPA 20-year Needs Assessment).



Wastewater One-Percenters

Connecticut's Nitrogen Trading Program (2002-2012)

1% of the Capital Cost

No Facility Upgrade

10 of 80 plants: Process changes @ \$50,000 per plant

6 mg/L total-N

99-Percenters; Everybody Else

Facility Upgrades

48 of 80 plants: N-Removal upgrades @ \$6.15 Million per plant

6 mg/L total-N

Phosphorus Experience





Re-Engineering

Existing equipment is used differently to provide better habitats.
Making the treatment plant a good “home” for bacteria.



BOD/TSS Removal

Biological Nitrogen Removal

Aerobic - Ammonia Removal

Anoxic - Nitrate Removal

Biological Phosphorus Removal

Anaerobic - VFA production

Aerobic - bio-accumulation

How to make any treatment plant remove Nitrogen & Phosphorus



Oxygen-Rich, low BOD environment

Nitrogen

Ammonia Removal – Nitrification

Phosphorus

Dissolved Phosphorus converted to TSS (particulate Phosphorus)

Oxygen-Poor, high BOD environment

Nitrogen

Nitrate Removal – Denitrification

Phosphorus

Volatile Fatty Acid (VFA) production; if anaerobic/fermentative

TSS Removal

Nitrogen

12% of MLSS is Nitrogen (8 mg/L TSS = 1 mg/L total-N)

Phosphorus

3-5% of MLSS is Phosphorus (2 mg/L TSS = 0.1 mg/L total-P)

Case Study

Plainfield (CT) Village Plant – ReEngineered for N&P Removal

Design Flow: 0.5 MGD

Actual: 0.2 MGD

Effluent total-N

Before Changes: 20 mg/L
(10 TKN, 8 Ammonia, 10 Nitrite + Nitrate)


After Changes: 6 mg/L
(2.5 TKN, 0.5 Ammonia, 3.5 Nitrite + Nitrate)

Effluent total-P


Before Changes: 3 mg/L
After Changes: 0.75 mg/L



Plainfield Village



Plainfield Village
Gravity Thickener as Post-Anoxic Denitrification





Nitrogen and Phosphorus Removal



Costly Facility Upgrade!

... or ...


Process Changes?

Compliance may be easier and
and more affordable than you've
been led to believe...

**trust
yourself.
you know
more than you
think you do.**

(dr. spock)

Let's
begin



Biological Nitrogen Removal

Organic-Nitrogen (org-N)



Ammonia (NH_3)



Nitrate (NO_3)




Nitrogen Gas (N_2)

Ammonia Removal - Nitrification:
Bacteria Convert Ammonia to Nitrate

Nitrate Removal - Denitrification:
Bacteria Convert Nitrate to Nitrogen Gas





Re-Engineering O&M for Nitrogen Removal





Ammonia Removal



Nitrate Removal

Ammonia Removal





Ammonia Removal - Nitrification

Create a Habitat to motivate and support Bacteria that remove Ammonia (NH_3)

Dissolved Oxygen (DO)

+100 ORP

Low BOD

Old Sludge (High MLSS, High MCRT/SRT; Low F:M)

Alkalinity to keep pH from dropping

Time (HRT)

Temperature



Ammonia Removing Technologies

Extended aeration



Dissolved Oxygen (DO) & ORP

Old sludge (High MLSS / MCRT / SRT;
Low F:M)

Low BOD


Time (HRT)

Alkalinity to keep pH from dropping



Two-stage trickling filter

Nitrate Removal



Nitrate Removal - Denitrification

Create a Habitat so the Bacteria that Remove Nitrate (NO_3) will be motivated to do it...

Little to Zero DO

-100 ORP



Surplus BOD (High F:M)

Time (HRT)

They give back one-half of the
Alkalinity that the Nitrifiers removed



Nitrate Removal Habitats





Nitrate Removing Technologies

Post-Anoxic Denitrification

Pre-Anoxic Denitrification (MLE:
Modified Ludzack-Ettinger)

SBR, or Cycling between
Nitrification and Denitrification

Oxidation Ditch (Bardenpho)

HABITAT


Little to Zero DO

-100 or lower ORP

Surplus BOD (High F:M)


Time (HRT)






Post-Anoxic Denitrification






Pre-Anoxic: MLE Process






Sequencing Batch Reactor (SBR)






Oxidation Ditch: Bardenpho Process



Nitrogen Removal Simplified



Ammonia Removal - Nitrification

High DO / ORP

Low BOD

Plenty of Alkalinity

High Sludge Age

Long Retention time

Nitrate Removal - Denitrification

Low DO / ORP

High BOD

Long Retention time

Gives back alkalinity



P

15

30.974



Phosphorus

Phosphorus: Soluble and Particulate

Soluble Phosphorus

Convert to TSS (Particulate)

Biological P removal

Chemical P removal

Particulate Phosphorus

Remove phosphorus by removing TSS



Phosphorus Removal Strategy

Convert up to 0.05 mg/L of Soluble Phosphorus to TSS (Particulate)

Biologically

Chemically

Particulate Phosphorus

Remove as much TSS as necessary to meet Phosphorus Limit

Rule of Thumb: $2 \text{ mg/L TSS} = 0.1 \text{ mg/L t-P}$



TSS Removal Requirements

If all but 0.05 mg/L of Soluble Phosphorus is Converted to Particulate Phosphorus (Biologically and/or Chemically)

And, if Effluent TSS is 5% total-Phosphorus, Effluent TSS cannot exceed the numbers shown in the table...

P Limit	max TSS
0.1	1
0.2	3
0.3	5
0.4	7
0.5	9
0.6	11
0.7	13
0.8	15
0.9	17
1.0	19
1.1	21
1.2	23
1.3	25
1.4	27
1.5	29



Habitats



... followed by ...

Aerobic Zone
Phosphorus Uptake by PAOs
("Luxury Uptake")


Anaerobic Zone
Volatile Fatty Acid (VFA)
production




Anaerobic Zone - Volatile Fatty Acid (VFA) formation

Bacteria create VFAs

AND



. . . . In the process, the Bacteria release
some of their cellular Phosphorus
into solution



Aerobic Zone



Phosphorus Accumulating Organisms (PAO) concentrate soluble Phosphorus.

PAOs contain 3 times as much Phosphorus as “regular” bacteria do. The phosphorus concentration in the mixed liquor increases from <2% total-P to as much as 5% total-P.



Biological Phosphorus Removal

ANAEROBIC zone for VFA production

... followed by

AEROBIC zone for Phosphorus uptake
by PAO bacteria



Anaerobic Zone (Fermentation)

Mainstream

Pre- Anaerobic Zone

Modify Pre-Anoxic

Modify Existing Tanks

Sidestream

RAS piping

Gravity Thickener

Primary Sludge

WAS

Combined Primary & Secondary

Sludge Storage

Septage



Chemical Phosphorus Removal

*Soluble ortho-Phosphate is taken out of solution and made into TSS.
The particulate Phosphorus is settled.*

Iron

Ferric

Ferrous

Aluminum

Alum

PAC

Sodium Aluminate



Phosphorus Removal

Convert soluble Phosphorus to particulate Phosphorus

Biological: Anaerobic (Fermentation) followed by Aerobic

Chemical: Iron or Aluminum compound

Remove the TSS that contains the particulate Phosphorus

Achieving low total-P compliance requires ...

Low to almost zero soluble P

Low to almost zero effluent TSS



Case Studies



TREATMENT PLANT OPERATOR
tpo
DEDICATED TO MUNICIPAL WASTEWATER PROFESSIONALS

A Lot of Ingenuity

profile

Suffield (Conn.) Water Pollution Control Facility

BUILT: 1989

SERVICE AREA: City of Suffield (25 square miles)

EMPLOYEES: 8

FLOW: 2.83 mgd design, 1.3 mgd average, 4.5 mgd peak

TREATMENT LEVEL: Secondary

TREATMENT PROCESS: Activated sludge

RECEIVING WATER: Connecticut River

BIO-SOLIDS: Incinerated off site

WEB SITE:
<http://www.suffieldtownhall.com/content/2963166/default.aspx>

Not for reproduction. Reprinted from TPO™ / December 2010 / © 2010, CLE Publishing Inc., P.O. Box 220, Three Lakes, WI 54602 / 800-257-7222 / www.tponet.com

The cover of the TPO magazine features a photograph of two men, Bernie Gooch and Grant Weaver, standing in front of industrial equipment at the Suffield Water Pollution Control Facility. The man on the left is wearing a light blue shirt and jeans, while the man on the right is wearing a blue button-down shirt and khaki pants. They are both smiling at the camera. The background shows various pieces of machinery and a concrete structure, likely part of the wastewater treatment process.

Greater than 50% Nitrogen Reduction

Greater than 50% Phosphorus Reduction

Capital Cost: as little as ZERO

No New Tanks

O&M: generally, a cost SAVINGS

No Chemicals

Carbon Footprint: REDUCED

Re-Engineering O&M – Optimizing Existing Equipment

Ongoing Monitoring of ...

Ammonia

Nitrite + Nitrate

Alkalinity

ORP

Using ...

In-line instrumentation connected to SCADA

Hand-held equipment

Field Test Kits such as Test Strips

And ...

Ongoing Process Changes to Optimize Habitats



Re-Engineering for Nitrogen Removal



	<u>t-N Before</u>	<u>t-N After</u>
Suffield, CT	6.7	2.0
Montague, MA	11	3.5
Windsor Locks, CT	6.5	4.5
East Hampton, CT	11	5.5
Plainfield Village, CT	20	6.0
Manhattan, MT	12	7
Conrad, MT	12	7
Amherst, MA	25	8
Plainfield North, CT	15	8
Farmington, CT	12	8
Chinook, MT	25	12




Re-Engineering for Phosphorus Removal



	<u>t-P Before</u>	<u>t-P After</u>
Keene, NH	3.0	0.2
East Haddam, CT	3.5	0.4
Montague, MA	5.5	0.6
Suffield, CT	3.0	0.7
Plainfield Village, CT	3.0	0.8





Welcome to
CASE STUDIES



Trickling Filters, Lagoons, etc.



Case Study – Nitrogen & Phosphorus Removal Plainfield, Connecticut Village Plant

Design Flow: 0.5 MGD

Actual: 0.2 MGD

Effluent total-N

Before Changes: 20 mg/L
(10 TKN, 8 Ammonia, 10 Nitrite + Nitrate)

After Changes: 6 mg/L
(2.5 TKN, 0.5 Ammonia, 3.5 Nitrite + Nitrate)


Effluent total-P

Before Changes: 3 mg/L


After Changes: 0.75 mg/L



Plainfield Village



Plainfield Village
Gravity Thickener as Post-Anoxic Denitrification



Plainfield Village



Case Study – Nitrogen & Phosphorus Removal Montague, Massachusetts

Design Flow: 1.8 MGD

Actual: 1.0 MGD

Effluent total-N

Before Changes: 11 mg/L

(6.0 TKN, 4.2 Ammonia, 5.0 Nitrite + Nitrate)

After Changes: 3.5 mg/L

(2.0 TKN, 0.5 Ammonia, 1.5 Nitrite + Nitrate)

Effluent total-P

Before Changes: 2.5 mg/L


After Changes: 0.6 mg/L



**Primary
Clarifiers**

**Aeration
Tanks**

**Secondary
Clarifiers**



Montague, Massachusetts


Montague



**Primary
Clarifiers**

**Aeration
Tanks**

**Secondary
Clarifiers**



Montague Process®




**Primary
Clarifiers**



**Aeration
Tanks**



**Secondary
Clarifiers**



Montague Process®

Montague



Case Study – Nitrogen Removal Plainfield, Connecticut North Plant

Design Flow: 1.0 MGD

Actual: 0.4 MGD

Effluent total-N

Before Changes: 15 mg/L

(5 TKN, 2 Ammonia, 10 Nitrite + Nitrate)

After Phase I Changes: 8 mg/L

(2 TKN, 0.5 Ammonia, 6 Nitrite + Nitrate)

After Phase II Changes: 5 mg/L (anticipated)

(2 TKN, 0.5 Ammonia, 3 Nitrite + Nitrate)

Effluent total-P

Before Changes: 2.0 mg/L

After Phase II: 0.75 mg/L (anticipated)



Plainfield North



Primary
Clarifier



Aeration
Tank




Secondary
Clarifier



*North Plant
Plainfield, Connecticut*



**Primary
Clarifier**



**Aeration
Tank**




**Secondary
Clarifier**



*North Plant
Plainfield, CT*




Cycling Aeration to create ideal habitats for Ammonia and Nitrate removal



□□□□□□□□
□□□□□□□□

□□□□□□□□
□□□□

□□□□□□□□
□□□□□□□□




*North Plant
Plainfield, CT
Drover Process®*



Drover Process[®]

Convert Primary Clarifiers to pre-Anoxic tanks (MLE)



Case Study – Phosphorus Removal Keene, New Hampshire

Design Flow: 6.0 MGD

Actual: 3.0 MGD

Effluent total-N

Before & After: 8 mg/L


(3.5 TKN, 1.5 Ammonia, 4.5 Nitrite + Nitrate)

Effluent total-P

Before Changes: 3.0 mg/L

After Changes: 0.2 mg/L





Keene, New Hampshire



Keene, New Hampshire





Case Study – Phosphorus Removal East Haddam, Connecticut

Design Flow: 0.055 MGD

Actual: 0.015 MGD

Effluent total-N


Before & After: 6.5 mg/L
(2 TKN, 0.5 Ammonia, 3.5 Nitrite + Nitrate)

Effluent total-P

Before Changes: 3-4 mg/L

After Changes: 0.35 mg/L





East Haddam, Connecticut



East Haddam, Connecticut



Case Study – Nitrogen Removal East Hampton, Connecticut

Design Flow: 2.0 MGD

Actual: 1.5 MGD

Effluent total-N

Before Changes: 11 mg/L
(2 TKN, 0.5 Ammonia, 9 Nitrite + Nitrate)

After Changes: 6 mg/L
(2 TKN, 0.2 Ammonia, 4 Nitrite + Nitrate)


Effluent total-P

Before & After: 1-3 mg/L




East Hampton, Connecticut






East Hampton, Connecticut









Percent Nitrate Removal as Recycle Pump Rate Increases





Water Planet's Observation
100% Recycle Rate






200% Recycle Rate



Mixed Liquor Recycle



300% Recycle Rate



Case Study – Nitrogen & Phosphorus Removal Suffield, Connecticut

Design Flow: 2.0 MGD

Actual: 1.0 MGD

Effluent total-N

Before Changes: 7 mg/L

(3 TKN, 0.5 Ammonia, 4 Nitrite + Nitrate)

After Changes: 2.0 mg/L

(1 TKN, 0.1 Ammonia, 1 Nitrite + Nitrate)

Effluent total-P


Before Changes: 3.0 mg/L

After Changes: 0.7 mg/L



Suffield, Connecticut





Suffield, Connecticut



Re-Engineering O&M for Nitrogen & Phosphorus Removal



Oxygen-Rich, low BOD environment

Nitrogen

Ammonia Removal – Nitrification

Phosphorus

Dissolved Oxygen converted to TSS (particulate Phosphorus)

Oxygen-Poor, high BOD environment

Nitrogen

Nitrate Removal – Denitrification

Phosphorus

Volatile Fatty Acid (VFA) production; if
anaerobic/fermentative

TSS Removal


Nitrogen

12% of MLSS is Nitrogen (8 mg/L TSS = 1 mg/L total-N)

Phosphorus

3-5% of MLSS is Phosphorus (2 mg/L TSS = 0.1 mg/L total-P)

Questions, Comments, Discussion





Making clean water affordable

